



### **Additional NFPA 285 Information**

- 1) Maximum Lightweight Stone Masonry Unit Parameters to meet compliance with NFPA 285

Based on the test assembly, any decorative piece of any reasonable shape may be allowed as long as either condition below is met:

- A) The per foot volume does not exceed 3,456 cubic inches per foot of length.
  - B) The per foot cross sectional area does not exceed 288 square inches.
- 2) To meet compliance with NFPA 285, Backer rod to be minimum 4# Delta Safing Board cut to 1" x 2" deep pieces.
  - 3) To meet compliance with NFPA 285, manufacturer must apply Piazza Adhesive to recessed back side of Lightweight Stone Masonry Unit  $\frac{1}{4}$ " thick to seal in foam.